

Speed Post

S-29020/98/75(2)/R/2006/EHQ
भारत सरकार / Government of India
अन रब रोजगार मंत्रालय
Ministry of Labour & Employment
खाना दूर्घटना समिति कार्यालय
Directorate General of Mines Safety

No. 306/944/EHQ, Dharbad, dated 14-03-2017
From:
Chief Inspector of Mines
Director General of Mines Safety,
P.O. & Distt: Dharbad - 826 013.

To
Shri Naresh B. Dhoote, Technical Director,
M/s. Flameproof Equipments Pvt. Ltd.,
'Flameproof House',
Plot No.B-29, (Near Monginis Cake Factory),
New Link Road, Andheri (West),
Mumbai- 400 053.

Sub: Renewal of DGMS approval no. 125 of 2002 Under Regulation 75(2) of the Oil Mines Regulations, 1984 for Flameproof/Weatherproof Tube Light Fitting in cast aluminium L.M.b construction, type-FLP-RH-1650 conforming to IS/IEC 60079-1:2007, IEC 60529:2001 and IS/IEC 60079-0:2001 for use in Gas Group IIIB and Zone 1 & Zone 2 hazardous areas of Oil Mines,

Ref: CIMFR test report No. CIMFR/TG/SR/300 dated 23.07.2013.

IDENTIFICATION MARK
DGMS APPROVAL NO. 125 OF 2002

Dear Sir,

Please refer to your letter No. FEPI/HBD/DGMS/4149/2015 dated 08.10.2015 and subsequent correspondence thereupon the above subject.

Based on DGMS approval no. 125 of 2002 issued vide Directorate's letter no. 306/944/EHQ dated 20.06.2002, BIS license no. CMY-L-0850855 and CIMFR test report under reference, I hereby renew the approval upto 25.09.2020 from the date of expiry i.e. from 25.09.2015 for use in Gas Group IIIB and Zone 1 & Zone 2 hazardous areas of Oil Mines, subject to compliance with conditions stipulated in the original approval as well as annexure-A enclosed with this renewal letter.

Please note that application for renewal should be made at least one month before the date of expiry of the approval.

Yours faithfully,

Annexure

DGMS approval no. 125 of 2002 renewed vice Directorate's letter
no...../EHQ dated.....

Conditions for renewal of DGMS approval no. 125 of 2002 under Regulation 79(2) of the Oil Mines Regulations, 1984 for Flameproof/Weatherproof Tube Light Fitting in cast aluminium LM-5 construction, type-FLP-RH-1850 conforming to IS/IEC 60079-1:2007, IEC 60079-0:2000 and IS/IEC 60079-0:2004 for use in Gas Group IIB and Zone 1 & Zone 2 hazardous areas of Oil Mines.

1. (i) Every unit shall carry conspicuously in a permanent manner the aforesaid identification mark, i.e. 'DGMS APPROVAL NO. 125 of 2002 issued vice DGMS letter no./EHQ dated.....' In addition, every unit shall also carry permanently this Directorate's approval mark as given below :



- (ii) In the nameplate marking shall be in accordance with the applicable requirements of the relevant standards.
2. (a) The design of the electrical circuit shall not be changed without obtaining prior approval from this Directorate.
(b) Conspicuous warning inscriptions against opening the cover of the main enclosure or of any apparatus which gives access to the flameproof enclosures or live parts or which is designed to receive cable attachment unless the supply to the unit is isolated at source, shall be affixed permanently on the respective part to ensure that all live parts within the unit are made dead and safe.
3. Spare parts shall be made readily available to the user as and when required for proper maintenance of the equipment.
4. (a) The customer shall be supplied the copy of this approval letter, the test report from the testing laboratory with the lab certified drawing , an extract of the condition & special conditions, maintenance schedule, if any, recommended by the testing laboratory in their test report(s) so as to maintain safety features of apparatus/equipment.
(b) The customer shall also be provided a copy of factory test report along with drawings, instruction manual on the installation, operation and maintenance of the equipment and spares parts catalogue at the time of delivery of the equipment.
5. The user shall furnish the performance report of the equipment directly to this Directorate after one (01) year of actual use.
6. Any modification to the equipment that might be considered necessary at a later

7. An officer of this Directorate may at any time draw a sample either from the factory or from the User and get it tested at the cost of the manufacturer. If the test
8. If there occurs any revision of standards applicable to the product/equipment, the manufacturer shall get the product/equipment tested as per revised standards and submit test reports to the customer for information and to this Directorate for further approval/renewal.
9. The cable entry devices, threaded adaptors and stoppers plugs shall be suitable for the equipment and to be considered as a part of equipment (not a component). The cable entry device and cabling methods used shall be suitable for their intended duty and for the special type of coal used in mining. Such cable entry devices shall be duly certified as per relevant IS/IEC standards.
10. In case of any permissible variations issued from this Directorate, they shall also be read along with this letter and the original approval letter;
11. While seeking renewal of approval, valid BIS license in the case of Indian manufacturers and in case of foreign manufacturers QAR/QAN, as may be applicable, shall be submitted and the same shall remain valid as long as the apparatus is manufactured and marketed.
12. The approval is renewed upto 23.09.2020 from the date of expiry i.e. from 23.09.2015.
13. The equipment manufactured subsequently shall be identical to the model type tested at CMMR vide test report No. C-M-R/TC/SR/300 dated 23.07.2013.
14. At the time of applying for renewal, details of supply with name of mines, purchase order and date shall be furnished with the application.
15. If at any time any of the conditions subject to which this approval has been granted, is violated or not complied with, this approval shall be deemed to have been revoked with immediate effect.
16. The above approval may be exercised or withdrawn at any time, if considered so necessary in the interest of safety and is being issued without prejudice to any other provisions of law which may be or may become applicable at any time.

(Prasenja Kumar Sarker)
Chief Inspector of Mines