



S-29020/131/181(3)/R/2006/EHQ
भारत सरकार/Government of India
श्रम एवं रोजगार मंत्रालय
Ministry of Labour & Employment
खात सुरक्षा महानिदेशालय/
Directorate General of Mines Safety

Speed Post



संख्या 83/224

/वि. नु., धनबाद, दिनांक

18-02-2017

From
Director General of Mines Safety
Directorate General of Mines Safety,
P.O & Distt: Dhanbad - 826 016.

To
Shri K.N. Neelkant – Managing Director
M/s. Crompton Greaves Ltd.
A-6/2, MIDC Industrial Area,
Ahmednagar-414 111 (Maharashtra).

Sub: Renewal of DGMS approval No. 145 Group-I of 1977 under Regulation 181 (3) of the Coal Mines Regulations, 1957 for flameproof fan cooled squirrel cage induction motor rated at 3 HP (2.2 KW), 380/440 V, 3 phase, 50 Hz, 3000 RPM with class 'F' insulation in frame size-E100L manufactured by M/s Crompton Greaves Ltd., Ahmednagar conforming to IS/IEC 60079-1:2007 and IS/IEC 60079-0:2004 for use in belowground Coal Mines.

Ref: ERTL test report No. ERTL(E)/TES/C184/0070/11-12 dated 10.12.2012 and SGS Baseefa Test Certificate No. IECEX BAS 06.0050X dated 02.10.2013.

IDENTIFICATION MARK
DGMS APPROVAL NO. 145 Group-I of 1977

Dear Sir,

Please refer to your letter No. DGMS/REN/2015-16/02 dated 25.08.2016 and subsequent correspondence thereupon the above subject.

Based on DGMS approval No. 145 Group-I of 1977 issued by this Directorate's letter No. 83/75/1201/EHQ dated 03.10.1977, BIS Licence No. CM/L-0870053 and above test reports under reference, I hereby renew the approval **upto 05.12.2018 from the date of expiry i.e. from 05.12.2016** for use belowground in Coal Mines, subject to compliance with conditions stipulated in the original approval as well as annexure enclosed with this renewal letter.

The application for renewal should be made at least **three (03) months** before the date of expiry of the approval.

Yours faithfully,

(Rahul Gupta)

Director General of Mines Safety


End : Annexure

DGMS approval No. 145 Group-I of 1977 renewed by this Directorate's letter No. 83/224/EHQ dated 10-01-2017

Conditions for renewal of DGMS approval No. 145 Group-I of 1977 Under Regulation 181 (3) of the Coal Mines Regulations, 1957 for flameproof fan cooled squirrel cage induction motor rated at 3 HP (2.2 KW), 381/440 V, 3 phase, 50 Hz, 3000 RPM with class 'E' insulation in frame size-E100L manufactured by M/S Crompton Greaves Ltd., Ahmednagar conforming to IS/IEC 60079-1:2007 and IS/IEC 60079-0:2004 for use in belowground Coal Mines.

1. (i) Every unit shall carry conspicuously in a permanent manner the aforesaid identification mark, i.e. DGMS APPROVAL NO. 145 Group-I of 1977 renewed vide DGMS letter No. 83/224/EHQ dated 10-01-2017

In addition, every unit shall also carry permanently this Directorate's approval mark as given below :



(ii) In the nameplate marking shall be in accordance with the applicable requirements of the relevant standards.

2. (a) The design of the electrical circuit shall not be changed without obtaining prior approval from this Directorate.
- (b) Conspicuous warning inscriptions against opening the cover of the main enclosure or of any apparatus which gives access to the flameproof enclosures on live parts or which is designed to receive cable attachment unless the supply to the unit is isolated at source, shall be affixed permanently on the respective part to ensure that all live parts within the unit are made dead and safe.
3. Spare parts shall be made readily available to the user as and when required for proper maintenance of the equipment.
4. (a) The customer shall be supplied the copy of this approval letter, the test report from the testing laboratory with the lab certified drawing, an extract of the condition & special conditions, maintenance schedule, if any, recommended by the testing laboratory in their test report(s) so as to maintain safety features of apparatus/equipment.
- (b) The customer shall also be provided a copy of factory test report along with drawings, instruction manual on the installation, operation and maintenance of the equipment and spares parts catalogue at the time of delivery of the equipment.
5. The user shall furnish the performance report of the equipment directly to this Directorate after one (01) year of actual use.
6. While seeking renewal of approval, valid BIS license in the case of Indian manufacturers and in case of foreign manufacturers QAR/QAN, as may be applicable, shall be submitted and the same shall remain valid as long as the apparatus is manufactured and marketed.

K. Srinivasan
10/01/2017

7. If there occurs any revision of standards applicable to the product/equipment, the manufacturer shall get the product/equipment tested as per revised standards and submit test reports to the customer for information and to this Directorate for further approval/renewal.
8. The cable entry devices, threaded adaptors and stopping plugs shall be suitable for the equipment and be considered as a part of equipment (not a component). The cable entry device and cabling methods used shall be suitable for their intended duty and for the special type of cable used in mining. Such cable entry devices shall be duly certified as per relevant IS/IEC standards.
9. In case of any permissible variations issued from this Directorate, they shall also be read along with this letter and the original approval letter.
10. Any modification to the equipment that might be considered necessary at a later date shall be effected upon being so directed by this Directorate.
11. An officer of this Directorate may at any time draw a sample either from the factory or from the user and get it tested at the cost of the manufacturer. If the test reports are not satisfactory, this approval shall be deemed to be suspended.
12. The approval is renewed upto 05.12.2018 from the date of expiry i.e. from 05.12.2016.
13. In case of aluminium die-cast rotor of the motor, the rotor shall not be dismantled, assembled or kept exposed in the explosive gassy atmospheres to prevent incendive sparking. A caution plate "Aluminium Die-Cast Rotor; Not to be dismantled, assembled or kept exposed in explosive gas atmosphere" shall be provided at conspicuous place without affecting Flameproof features of the motor, indicating that the motor is having aluminium die-cast rotor. Operation & maintenance manual of the motor shall also indicate the danger for aluminium die cast rotor due to incendive sparking.
14. The equipment manufactured subsequently shall be identical to the proto type tested at ERTL vide test report No. ERTL (E)/TES/C184/0070/11-12 dated 10.12.2012 and SGS Basecota Test Certificate No. IECEx BAS 06.0050X dated 02.10.2013.
15. At the time of applying for renewal, details of supply with name of mines, purchase order and date shall be furnished with the application.
16. If at any time any of the conditions subject to which this approval has been granted, is violated or not complied with, this approval shall be deemed to have been revoked with immediate effect.
17. The above approval may be amended or withdrawn at any time, if considered so necessary in the interest of safety and is being issued without prejudice to any other provisions of law which may be or may become applicable at any time.


(Rahu Guha)
Director General of Mines Safety