

संगीत यात्रा

S-2020/05/181(3)/R/2013/E-IQ
भारत सरकार/Government of India
गन २५ रोपनार मंत्रलय
Ministry of Labour & Employment
कानून सुवेचालन विभाग
Directorate General of Mines Safety

No. 587/94 A-IQ, Dhanbad, dated 06-01-2017

From:
The Director General of Mines Safety
Directorate General of Mines Safety,
P.O. & Distt: Dhanbad-826 016.

To:
Dr. S.K. Maheswaran Proprietor
M/s. G.E. Electricals & Technocrats
Dhansar Chowk, Dhansar - 826 106
Distt - Dhanbad (Jharkhand)

Sub: Renewal of Approval no. 680 of 2011 under Regulation 181 (3) of the Coal Mines Regulations, 1957 for Flameproof and weatherproof to operate switch, "SS & CI grade FG 150 construction rated at 12V/24V DC, 5 A (max.) designated by Cat. No. TS 01 manufactured by M/S G.E. Electricals & Technocrats, Dhanbad conforming to IS/IEC 60079-1 : 2007, IS/IEC 60529 : 2001 and IS/IEC 60079-0:2004 for use in belowground coal mines.

Ref: CIMFR test report No. CIMFR/TC/P/H668 dated 07.01.2013.

IDENTIFICATION MARK
DGMS APPROVAL NO. 680 OF 2014

Dear Sir,

Please refer to your letter No. 16-17/1000 dated 01.11.2016 and subsequent correspondence thereupon the above subject.

Based on Approval no. 680 of 2014 issued by this Directorate's letter no. 587/123/E-IQ dated 11.09.2014, BIS License no. CM/L-5/2006-09 etc above test report under reference, I hereby renew the approval upto 11.09.2018 from the date of expiry i.e. from 11.09.2016 for use in underground in Coal Mines, subject to compliance with conditions stipulated in the original approval as well as annexure enclosed with this renewal letter.

Please note that application for renewal should be made at least three (3) months before the date of expiry of the approval.

Yours faithfully,


(Rahul Gohil)
Director General of Mines Safety

End : Annexure

DGMS approval no. 680 of 2014 issued by this Directorate's letter no. 587/24/JHQ dated 06-01-2017.

Conditions for renewal of Approval no. 680 of 2014 under Regulation 181 (3) of the Coal Mines Regulations, 1957 for flameproof and weatherproof temperature switch, in SS & CI grade PG 150 construction rated at 12V/24V DC, 5 A (max.) designed by Cat. No. 1S C1 manufactured by M/S G.E. Electricals & Technocrats, Dhanbad conforming to IS/IEC 60079-1 : 2007, IS/IEC 60079-20 : 2007 and IS/IEC 60079-0:2004 for use in belowground coal mines.

1. Every unit shall carry conspicuously in a permanent manner the aforesaid certification mark, i.e. 'DGMS APPROVAL NO. 680 of 2014 issued vide DGMS letter no. 587/24/JHQ dated 06-01-2017'.

In addition, every unit shall also carry permanently this Directorate's approval mark, as below:



2. (a) The design of the electrical circuit shall not be changed without obtaining prior approval from this Directorate.
(b) Conspicuous warning inscriptions against opening the cover of the main enclosure or of any apparatus which gives access to the flammable atmospheres on live parts or which is designed to receive cable attachment unless the supply to the unit is isolated at source, shall be affixed permanently on the respective part to ensure that all live parts within the unit are made dead and safe.
3. Spare parts shall be made readily available to the user as and when required for proper maintenance of the equipment.
4. (a) The customer shall be supplied the copy of this approval letter, the test report from the testing laboratory with the iso certified drawing, an extract of the condition & special conditions, maintenance schedule, if any, recommended by the testing laboratory in their test report(s) so as to maintain safety features of apparatus/equipment.
(b) The customer shall also be provided a copy of factory test report along with drawings, instruction manual on the installation, operation and maintenance of the equipment and spares parts catalogue at the time of delivery of the equipment.
5. The user shall furnish the performance report of the equipment directly to this Directorate after one (01) year of actual use.
6. Any modification to the equipment that might be considered necessary at a later date shall be effected upon being so directed by this Directorate.

Contd P-2

7. An officer of this Directorate may at any time draw a sample either from the factory or from the user and get it tested at the cost of the manufacturer. If the test reports are not satisfactory, this approval shall be deemed to be suspended.
8. If there occurs any revision of standards applicable to the product/equipment, the manufacturer shall get the product/equipment tested as per revised standards and submit test reports to the customer for information and to this Directorate for further approval/renewal.
9. The cable entry devices, threaded adaptors and stoppers plugs shall be suitable for the equipment and be considered as a part of equipment (not a component). The cable entry device and cabling methods used shall be suitable for their intended duty and for the specific type of cable used in mining. Such cable entry devices shall be duly certified as per relevant IEC/IEC standards.
10. In case of any permissible variations issued from this Directorate, they shall also be read along with this letter and the original approval letter.
11. While seeking renewal of approval, valid BIS license in the case of Indian manufacturers and in case of foreign manufacturers, QAR/QAN as may be applicable shall be submitted.
12. The approval is reviewed upto 31.09.2018 from the date of issue i.e. from 11.09.2016.
13. The equipment manufactured subsequently shall be identical to the proto type tested at CIMFR test report no. CIMFR/TC//H668 dated 07.01.2013.
14. At the time of applying for renewal, details of supply with name of mines, purchase order and date shall be furnished with the application.
15. If at any time any of the conditions subject to which this approval has been granted, is violated or not complied with, this approval shall be deemed to have been revoked with immediate effect.
16. The above approval may be amended or withdrawn at any time, if considered so necessary in the interest of safety and is being issued without prejudice to any other provisions of law which may be or may become applicable at any time.



(DGM)
Director General of Mine Safety