

By Registered Air Mail



S.29020/36/181(3)/A/2015/EHQ
मार्ग सरकार/Government of India
मन वर राज्यादि मंत्रालय
Ministry of Labour & Employment
राजा चुरुषा निकामेश्वरालय/
Directorate General of Mines Safety



No. 483/454

/EHQ, Dhanbad, dated the

09-03-2017

From:
Chief Inspector of Mines
Directorate General of Mines Safety,
P.O & Distt: Dhanbad - 826 016,
Jharkhand (India).

To
Shri Shubhrawnik - Country Head
M/s. Joy Global (UK) Ltd.,
Kirkby Lane, Pinxton,
Nottinghamshire NG 16 6HX
United Kingdom.

Sub: Approval under Regulation 181 (3) of the Coal Mines Regulations, 1957 for flameproof and intrinsically safe electrical equipment (as per Annexure B), associated with the Feeder Breaker, Model UFB-14B-3 /C, manufactured by M/s. Joy Global (UK) Ltd for use in belowground coal mines in India.

Ref: Test Reports as per Annexure-B

IDENTIFICATION MARK
DGMS APPROVAL No. 723 ...of 2017

Dear Sir,

In reference to the field trial permission issued vide letter No. 265/LHQ dated 09.02.2016 and based on the performance report received from the Agent, Haldibari UG Mine of M/s. South Eastern Coalfields Ltd., Bokaro and test reports as referred above, I hereby accord approval for Flameproof and Intrinsically Safe electrical equipment (as per Annexure-B), associated with the Feeder Breaker, Model UFB-14B-3 /C, manufactured by M/s. Joy Global (UK) Ltd. for use in belowground coal mines in India for a period of five (05) years from the date of issue of this letter for use in belowground coal mines in India subject to compliance with conditions stipulated in Annexure-A.

The application for renewal should be made at least three (03) months before the date of expiry of the approval.

Yours faithfully,

(Prasanta Kumar Sarkar)
CHIEF INSPECTOR OF MINES

Enc : Annexure-A&B

Annexure-A

DGMS approval no. 723 of 2017 issued by Directorate's letter no. 483/454/THQ dated 09.03.2017

Conditions for DGMS approval under Regulation 181(3) of the Coal Mines Regulations, 1957 for flameproof and intrinsically safe electrical equipment (as per Annexure-B), associated with the Feeder Breaker, Model UFB-1/B 3-7C, manufactured by M/s. Ioy Global (UK) Ltd. for use in belowground coal mines in India.

1. Every Feeder Breaker, Model UFB-1/B 3-7C shall carry conspicuously in a permanent manner the aforesaid identification mark, i.e. "DGMS APPROVAL NO. 723 of 2017 approved by Directorate's letter No. 483/454/THQ dated 09.03.2017". In addition, every machine shall also carry permanently this Directorate's approval mark as below:



2. The relevant provisions of the Central Electricity Authority (Measures relating to Safety and Electric Supply) Regulations, 2010 shall be complied with in all matter relating to the installation, operation and maintenance of the equipment.
3. The electric supply to the machine shall be controlled from flameproof Gate and Box with intrinsically safe supply for control circuit of suitable rating along with sensitive earth leakage protection.
4. All covers, doors/access covers of the electrical equipment mounted on the equipment, on opening/removal which may expose live internal conductors, shall have warning instructions either by raised lettering or by other suitable means against such opening/removal of covers, doors and access covers, without isolating supply of energy to the equipment from its source.
5. The plug and socket assembly affixed to the motors/panel, if provided, will be so interlocked as to prevent removal of plug from the socket while alive.
6. Any replacement of part required for maintenance of the equipment which is directly or indirectly connected to the flameproof features thereof shall be supplied by the manufacturer as and when required.
7. The electrical equipment associated with the machine shall be checked by the Electrical Supervisor of the mine for their flameproofness. The condition of cables in the machine shall be checked at the beginning of each working shift and the findings thereof entered in a bound-page book maintained for that purpose which shall be duly signed by the Electrical Supervisor with the date.
8. The user shall furnish the performance report of the equipment directly to this Directorate after one (01) year of actual use.

9. (a) The customer shall be supplied the copy of this approval letter, the test report from the testing laboratory with the lab certified drawing , an extract of the condition & special conditions, maintenance schedule, if any, recommended by the testing laboratory in their test report(s) so as to maintain safety features of apparatus/equipment.
(b) The customer shall also be provided a copy of factory test report along with drawings, instruction manual on the installation, operation and maintenance of the equipment and spares parts catalogue at the time of delivery of the equipment.
10. The electrical and mechanical personnel who may be entrusted with the responsibility for the use, maintenance and operation of the machine shall be given adequate training.
11. The users in consultation with the manufacturer, shall frame a code of practice to provide the guidance of persons employed for installation, operation and maintenance of Feeder Breaker, Model UFB-14B-3-7/C and associated equipments, as well as to provide safety, health, convenience and discipline of persons so employed.
12. Technical assistance shall be provided by the supplier at the time of initial installation. The supplier shall also maintain close contact with the users to get themselves fully apprised of any difficulty that may be faced by the user with regards to the use, maintenance and operation of the equipment.
13. The fire resistant hydraulic fluid shall conform to the standards and parameters as prescribed in the DGMS/Mech/Tech.Ctr (Approval) No. 03, Dhanbad, dated 13.02.2015.
14. The high pressure hydraulic hoses supplied with the machine shall conform to the standards and parameters as prescribed in the DGMS/Mech/Tech.Ctr (Approval) No. 04, Dhanbad, dated 13.02.2015.
15. The cables in Machine shall conform to requirement or provisions of the DGMS Tech. Circular (Electrical) No. 12 dated 25.05.2015 and DGMS Tech. Circular (Electrical) Approval No. 01 dated 19.02.2010 in addition to the special requirement, if any, specifically for the safe operation of the machine.
16. If there occurs any revision of standards applicable to the product/equipment , the manufacturer shall get the product/equipment tested as per revised standards and submit test reports to the customer for information and to his Directorate for further approval/renewal.
17. While seeking renewal of approval, valid BIS license in the case of Indian manufacturers and in case of foreign manufacturers QAR/QAN for the associated flameproof / weatherproof / intrinsically safe apparatus, as may be applicable, shall be submitted and the same shall remain valid as long as the apparatus is manufactured and marketed.
18. The cable entry devices, threaded adaptors and staking plugs shall be suitable for the equipment and its considered as a part of equipment (not a component). The cable entry device and cabling methods used shall be suitable for their intended duty and for the specific type of cable used in mining. Such cable entry devices shall be

19. The approval is accorded for a period of five (05) years from the date of issue of this letter.
20. At the time of applying for renewal, details of supply with name of mines, purchase order and date shall be furnished with the application.
21. Any modification/alteration to the machine that might be considered necessary at a later date in the interest of safety or/and efficient handling, operation, maintenance and maneuverability of the machine shall be carried out upon being so directed.
22. If at any time any of the conditions subject to which this approval has been granted, is violated or not complies with, this approval shall be deemed to have been revoked with immediate effect.
23. The above approval may be amended or withdrawn at any time, if considered so necessary in the interest of safety and is being issued without prejudice to any other provisions of law which may be or may become applicable at any time.

Asafar Kumar Sarker
(Asafar Kumar Sarker)
Chief Inspector of Mines

Annexure - B

List of Flameproof and Intrinsically Safe electrical equipment associated with Feeder Breaker, Model UFB-14B-3-7C manufactured by M/s. Joy Global (UK) Ltd. in belowground coal mines in India under Regulation 181(3) of the Coal Mines Regulations, 1957 issued by Directorate's letter No. #83/484...../HQ, dated.....

| S. No | Description of electrical equipment | Manufacturer | Test report and date | Standard to which the test is conducted |
|-------|---|--------------|---|--|
| 1. | FLP Induction motor rated at 175 kW, 1100 V, 50 Hz, 3 phase, 4 pole | Builder | CIMFR/TCP/H641 dated 31.12.2012 | IS/IEC 60079-0:2004 IS/IEC 60079-1: 2007 |
| 2. | FLP Traction controller, Model - TC-05, rated at 1050V, 3 phase, 50 Hz | Joy | CIMFR/TCP/SH4/2 dated 07.10.2013 | IS/IEC 60079-0:2004 IS/IEC 60079-1: 2007 |
| 3. | FLP connector/switch box rated at 240V, 2:0VA max. MS model 00102-0018 | Joy | ERI(E)/I-S/105// 0053/09-12 dated 05.03.2013 | IS/IEC 60079-0:2004 IS/IEC 60079-1: 2007 |
| 4. | FLP Connection box, rated at 300A, 1100V, 3 phase | Joy | CIMFR/TCP/H67/3 Dated 10.01.2013 | IS/IEC 60079-0:2004 IS/IEC 60079-1: 2007 |
| 5. | H P Siren Model -HS1C | Hytronics | LRTI(E)/IES/0057/ 0025/01-13 Dated 05.03.2013 | IS/IEC 60079-0:2004 IS/IEC 60079-1: 2007 |
| 6. | H P Multi pin Connector (Ex Components) Rotor, upto 120v, 20A per pin | Joy | CIMFR/TCP/H75/ Dated 01.03.2013 | IS/IEC 60079-0:2004 IS/IEC 60079-1: 2007 IS/IEC 60523-2001 |
| 7. | H P Solenoid valve rated at 126V, 16.09 W | Joy | CIMFR/TCP/F/H66 dated 09.05.2012 | IS/IEC 60079-0:2004 IS/IEC 60079-1: 2007 IS/IEC 60529-2001 |
| 8. | H P Switch connection Box, rated at 10A, 250V | Joy | CIMFR/TCP/F/H661 dated 13.01.2014 | IS/IEC 60079-0:2004 IS/IEC 60079-1: 2007 |
| 9. | FLP/WP fluorescent luminaire rated at 250V model 4' 1A | Victor | CIMFR/TCP/I/H634 dated 26. 11.2013 | IS/IEC 60079-0:2004 IS/IEC 60079-1: 2007 IS/IEC 60529-2001 |
| 10. | FLP/WP A 42 range restrained connectors (Plug, Socket, plug coupler & test plug) rated upto 250A, 1300V | Victor | CIMFR/TCP/H47/5 dated 23.10.2013 | IS/IEC 60079-0:2004 IS/IEC 60079-1: 2007 IS/IEC 60529-2001 |

(Prasanta Kumar Sarkar)
(Prasanta Kumar Sarkar)
Chief Inspector of Mines